

Appendix 18

Measurement of sound absorption coefficient

Test Measurement of sound absorption coefficient in a reverberation room according to EN ISO 354 and evaluation according to EN ISO 11654

Client Ecophon AB
 Christer Persson

Object Hygiene Advance A
 Thickness: 20 mm.
 Panel size: 1200 mm x 600 mm.

Date of test December 11, 2008

Conditions Mounting depth: 200 mm.
 Surface area: 10,8 m².
 Room volume: 200 m³.
 Temperature at measurement on object/in empty room: 20/ 20 °C.
 Relative humidity at measurement on object/in empty room: 86/ 86 %.

Result Sound absorption class **B**.
 Weighted sound absorption coefficient $\alpha_w = 0,85$.

Practical sound absorption coefficient

